



COMBINATION AIR VALVE DETAIL IN ROADWAYS

N.T.S.

NOTES:

1. MANHOLES IN ROADWAYS REQUIRE CONCRETE COLLAR. IN UNIMPROVED AREAS, THE TOP OF LID SHALL BE SET 6 TO 12 INCHES ABOVE FINISH GRADE (NO CONCRETE COLLAR REQUIRED).
2. MANHOLE LID, RING, AND CONCRETE COLLAR TO BE CENTERED ON MANHOLE OPENING AND SET 1/4 INCH BELOW TOP OF ASPHALT.
3. MANHOLE VAULT MUST BE DESIGNED TO MEET AASHTO HS-20 LOADING.
4. TRACER WIRE IS REQUIRED ON PVC PIPE.

SHEET NO.

W11

COMBINATION AIR VALVE DETAIL
IN ROADWAYS

REVISIONS

DATE	DESCRIPTION	BY
10/2021	CHANGED TO CONCRETE VAULT	J.A.S.

CEDAR CITY
10 NORTH MAIN STREET
CEDAR CITY, UTAH 84720
PH. (435) 588-2963

SCALE: N.T.S.

DATE: 10/2021

DRAWN: T.B.M.

CHECKED: J.A.S.